

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0026:313 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *Fax (978) 731-8881

DESIGN: Models 4090-9005 and *4090-9006 Releasing Device Peripherals and Model 2975-9227 enclosure (for 4090-9005 only). *Models 2080-9056, -9057, -9067 and -9068 Abort Switches. *Models 2080-9059, -9060 Maintenance Switch with Lamp and *Model 2081-9048 Abort Supervision Module.
The peripherals connect to both the IDNet SLC and a NAC output on the 4010 control Unit (CSFM Listing No. 7170-0026:226) or *4100 series control unit (CSFM Listing No. 7170-0026:250 and 7165-0026:251). The NAC output may also be provided by *Models 4009-9201, or -9301 NAC expander (CSFM Listing No. 7300-0026:214). Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

RATING: 16-31 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as releasing device peripheral for use with listee's separately listed compatible fire alarm control units.

*Rev. 5-07-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager